



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT
ORELAP Accredited Lab#: OR-100013

Reported: 11/08/2012
Received: 10/10/2012
Sampled By: LN/lab
Work Order: 2284018

**C
L
I
E
N
T** **Parrett Mtn View Estates**
Attn: Kriss Schneider c/o Management Trust NW
21881 River Rd NE
St. Paul OR, 97137
Phone: 503-633-2666

Project: -
Project # : N/A
PWSID # : 4101498
PO # : -

Sampling Location: LaBrousse Rd.
Sample Matrix: Drinking Water

Lab Number	Sample Name	Sampled: 10/10/12 11:12 Sample Composition:						
2284018-01	Pumphouse inside HB							
Synthetic Organic Chemicals		Code	Method	Units	Result	MRL	EPA MCL	Analysis Date
Regulated Analyte								
† <i>Bis(2-ethylhexyl) phthalate</i>		2039	EPA 525.2	mg/L	ND	0.0013	0.006	11/01/2012 SUB-1

SUB-1 This analysis was subcontracted to UMPQUA Research Comp. ORELAP ID# OR100031

† All procedures for this analysis conform to NELAC standards.

ND = None detected **MRL** = Minimum Reporting Limit **MCL** = Maximum Contaminant Limit

Approved by:

Scott Dickman
Lab Director