

13035 SW Pacific Hwy  
 Tigard, OR 97223  
 Tel.: (503) 639-9311 Fax: (503) 684-1588

**Professional  
 Laboratory  
 Services**

**ANALYSIS REPORT**

ORELAP Accredited Lab#: OR-100013

Reported: 02/12/2015  
 Received: 02/11/2015  
 Sampled By: LN/lab  
 Work Order: 5042026


**C** Parrett Mtn View Estates  
**L** Attn: -  
**I** 21881 River Rd. NE  
**E** St Paul OR, 97137  
**N** Phone: 503-633-2666  
**T**

**Project:** -  
 Project # : N/A  
 PWSID # : 4101498

Sampling Location: La Brousse Rd.  
 Sample Matrix: Drinking Water

Lab Number	Sample Name	Sampled: 2/11/15 10:35		Sample Composition:					
<b>5042026-01</b>	<b>Inside pump house</b>								
Wet Chemistry		<b>Code</b>	<b>Method</b>	<b>Units</b>	<b>Result</b>	<b>MRL</b>	<b>EPA MCL</b>	<b>Secondary Standard*</b>	<b>Analysis Date/ Time</b>
†Nitrate as N		1040	EPA 300.0	mg/L	0.114	0.100	10	-	02/11/15 17:31

**ND** = None detected      **MRL** = Minimum Reporting Limit      **MCL** = Maximum Contamination Limit  
 †All procedures for this analysis conform to NELAC standards.

Approved by:   
 Scott Dickman  
 Lab Director

This report shall not be reproduced, except in full, without the written approval of the laboratory.