

**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

Reported: 08/07/2014
Received: 07/16/2014
Sampled By: LN/lab
Work Order: 4197015


C Parrett Mtn View Estates
L Attn: -
I 21881 River Rd. NE
E St Paul OR, 97137
N Phone: 503-633-2666
T

Project: -
Project # : N/A
PWSID # : 4101498

Sampling Location: LaBrousse Rd.
Sample Matrix: Drinking Water

Lab Number **Sample Name** **Sampled:** 7/16/14 9:45 **Sample Composition:**
4197015-01 **Inside pumphouse H.B.**

Metals (Total)	Code	Method	Units	Result	MRL	EPA MCL	Secondary Standard*	Analysis Date/ Time
†Antimony	1074	EPA 200.9	mg/L	ND	0.001	0.006	-	07/25/14 12:56
†Arsenic	1005	EPA 200.9	mg/L	ND	0.003	0.01	-	07/17/14 12:07
†Barium	1010	EPA 200.7	mg/L	ND	0.010	2	-	08/06/14 14:32
†Beryllium	1075	EPA 200.7	mg/L	ND	0.001	0.004	-	08/06/14 14:32
†Cadmium	1015	SM 3113B	mg/L	ND	0.0005	0.005	-	07/31/14 15:47
†Chromium	1020	EPA 200.7	mg/L	ND	0.020	0.1	-	08/06/14 14:32
†Lead	1030	EPA 200.9	mg/L	ND	0.002	0.015	-	07/21/14 12:22
†Mercury	1035	EPA 245.1	mg/L	ND	0.0003	0.002	-	07/29/14 16:54
†Nickel	1036	EPA 200.7	mg/L	ND	0.010	0.1	-	08/06/14 14:32
†Selenium	1140	EPA 200.9	mg/L	ND	0.005	0.05	-	07/25/14 15:29
Sodium	1052	SM3111B	mg/L	7.5	0.1	-	20	07/22/14 11:25
†Thallium	1165	EPA 200.9	mg/L	ND	0.00100	0.002	-	08/01/14 14:04
Wet Chemistry	Code	Method	Units	Result	MRL	EPA MCL	Secondary Standard*	Analysis Date/ Time
†Cyanide	1024	SM 4500-CN C	mg/L	ND	0.02	0.2	-	07/18/14 16:10
†Fluoride	1025	EPA 300.0	mg/L	0.44	0.10	4	-	07/16/14 17:55
†Nitrate as N	1040	EPA 300.0	mg/L	ND	0.100	10	-	07/16/14 17:55
†Nitrite as N	1041	EPA 300.0	mg/L	ND	0.0100	1	-	07/16/14 17:55



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

Reported: 08/07/2014

Received: 07/16/2014

Sampled By: LN/lab

Work Order: 4197015

C Parrett Mtn View Estates
L Attn: -
I 21881 River Rd. NE
E St Paul OR, 97137
N Phone: 503-633-2666
T

Project: -
Project # : N/A
PWSID # : 4101498

Sampling Location: LaBrousse Rd.
Sample Matrix: Drinking Water

ND = None detected **MRL** = Minimum Reporting Limit **MCL** = Maximum Contamination Limit

*This is a secondary standard and has no contaminant level. This is a guideline that is associated with aesthetic effect such as staining of plumbing fixtures, tastes, and odors.

†All procedures for this analysis conform to NELAC standards.

Approved by:

Scott Dickman
Lab Director

This report shall not be reproduced, except in full, without the written approval of the laboratory.