

**Professional  
Laboratory  
Services**

13035 SW Pacific Hwy  
Tigard, OR 97223  
Tel.: (503) 639-9311 Fax: (503) 684-1588

**ANALYSIS REPORT**

ORELAP Accredited Lab#: OR-100013


Reported: 07/28/2014  
Received: 07/21/2014  
Sampled By:  
Work Order: 4202010

**C** Parrett Mtn View Estates  
**L** Attn: -  
**I** 21881 River Rd. NE  
**E** St Paul OR, 97137  
**N** Phone: 503-633-2666  
**T**

**Project:** -  
Project # : N/A  
PWSID # : 4101498

Sampling Location: Various Homes  
Sample Matrix: Water

Lab Number	Sample Name	Sampled:	Sample Composition:					
<b>4202010-01</b>	<b>Owen Lot 8</b>	7/21/14 3:50						
Metals (Total)	<b>Code</b>	<b>Method</b>	<b>Units</b>	<b>Result</b>	<b>MRL</b>	<b>EPA MCL</b>	<b>Secondary Standard*</b>	<b>Analysis Date/ Time</b>
†Copper	1055	SM 3111B	mg/L	0.100	0.050	1.3	-	07/25/14 12:30
†Lead	1030	EPA 200.9	mg/L	0.003	0.002	0.015	-	07/23/14 14:03
<b>4202010-02</b>	<b>Harris Lot 39</b>	7/21/14 7:30						
Metals (Total)	<b>Code</b>	<b>Method</b>	<b>Units</b>	<b>Result</b>	<b>MRL</b>	<b>EPA MCL</b>	<b>Secondary Standard*</b>	<b>Analysis Date/ Time</b>
†Copper	1055	SM 3111B	mg/L	0.099	0.050	1.3	-	07/25/14 12:30
†Lead	1030	EPA 200.9	mg/L	0.003	0.002	0.015	-	07/23/14 14:03
<b>4202010-03</b>	<b>Marks Lot 48</b>	7/21/14 4:21						
Metals (Total)	<b>Code</b>	<b>Method</b>	<b>Units</b>	<b>Result</b>	<b>MRL</b>	<b>EPA MCL</b>	<b>Secondary Standard*</b>	<b>Analysis Date/ Time</b>
†Copper	1055	SM 3111B	mg/L	0.081	0.050	1.3	-	07/25/14 12:30
†Lead	1030	EPA 200.9	mg/L	0.003	0.002	0.015	-	07/23/14 14:03
<b>4202010-04</b>	<b>Mote Lot 43</b>	7/21/14 6:58						
Metals (Total)	<b>Code</b>	<b>Method</b>	<b>Units</b>	<b>Result</b>	<b>MRL</b>	<b>EPA MCL</b>	<b>Secondary Standard*</b>	<b>Analysis Date/ Time</b>
†Copper	1055	SM 3111B	mg/L	0.169	0.050	1.3	-	07/25/14 12:30
†Lead	1030	EPA 200.9	mg/L	0.002	0.002	0.015	-	07/23/14 14:03



**Professional  
Laboratory  
Services**

13035 SW Pacific Hwy  
Tigard, OR 97223  
Tel.: (503) 639-9311 Fax: (503) 684-1588

**ANALYSIS REPORT**

ORELAP Accredited Lab#: OR-100013

Reported: 07/28/2014  
Received: 07/21/2014  
Sampled By:  
Work Order: 4202010


**C** Parrett Mtn View Estates  
**L** Attn: -  
**I** 21881 River Rd. NE  
**E** St Paul OR, 97137  
**N** Phone: 503-633-2666  
**T**

**Project:** -  
Project # : N/A  
PWSID # : 4101498

Sampling Location: Various Homes  
Sample Matrix: Water

Lab Number	Sample Name	Sampled: 7/21/14 7:50		Sample Composition:				
<b>4202010-05</b>	<b>Wheeler Lot 62</b>							
Metals (Total)	Code	Method	Units	Result	MRL	EPA MCL	Secondary Standard*	Analysis Date/ Time
†Copper	1055	SM 3111B	mg/L	0.207	0.050	1.3	-	07/25/14 12:30
†Lead	1030	EPA 200.9	mg/L	0.004	0.002	0.015	-	07/23/14 14:03

**ND** = None detected      **MRL** = Minimum Reporting Limit      **MCL** = Maximum Contamination Limit  
†All procedures for this analysis conform to NELAC standards.

Approved by: 

Scott Dickman  
Lab Director

This report shall not be reproduced, except in full, without the written approval of the laboratory.