

**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

Reported: 07/24/2014
Received: 07/09/2014
Sampled By: LN/lab
Work Order: 4190032


C Parrett Mtn View Estates
L Attn: -
I 21881 River Rd. NE
E St Paul OR, 97137
N Phone: 503-633-2666
T

Project: -
Project # : N/A
PWSID # : 4101498

Sampling Location: LaBrousse Rd.
Sample Matrix: Drinking Water

Lab Number **Sample Name** **Sampled: 7/9/14 9:30** **Sample Composition:**
4190032-01 **Inside Pump House**

Synthetic Organic Chemicals	Code	Method	Units	Result	MRL	EPA MCL	Analysis Date	
Regulated Analyte								
† 1,2-Dibromo-3-chloropropane	2931	EPA 504.1	mg/L	ND	0.00002	0.0002	07/17/2014	SUB-5
† 1,2-Dibromoethane	2946	EPA 504.1	mg/L	ND	0.00002	0.00005	07/17/2014	SUB-5
† 2,4,5-TP (Silvex)	2110	EPA 515.3	mg/L	ND	0.005	0.05	07/18/2014	SUB-5
† 2,4-D	2105	EPA 515.3	mg/L	ND	0.001	0.07	07/18/2014	SUB-5
† Alachlor	2051	EPA 525.2	mg/L	ND	0.0002	0.002	07/21/2014	SUB-5
† Atrazine	2050	EPA 525.2	mg/L	ND	0.0003	0.003	07/21/2014	SUB-5
† Benzo (a) pyrene	2306	EPA 525.2	mg/L	ND	0.00004	0.0002	07/21/2014	SUB-5
† Bis(2-ethylhexyl) adipate	2035	EPA 525.2	mg/L	ND	0.004	0.4	07/21/2014	SUB-5
† Bis(2-ethylhexyl) phthalate	2039	EPA 525.2	mg/L	ND	0.0006	0.006	07/21/2014	SUB-5
† Carbofuran	2046	EPA 531.1	mg/L	ND	0.004	0.04	07/10/2014	SUB-5
† Chlordane	2959	EPA 508	mg/L	ND	0.00025	0.002	07/10/2014	SUB-5
† Dalapon	2031	EPA 515.3	mg/L	ND	0.005	0.2	07/18/2014	SUB-5
† Dinoseb	2041	EPA 515.3	mg/L	ND	0.0005	0.007	07/18/2014	SUB-5
† Diquat	2032	EPA 549.2	mg/L	ND	0.002	0.02	07/10/2014	SUB-5
† Endothall	2033	EPA 548.1	mg/L	ND	0.01	0.1	07/14/2014	SUB-5
† Endrin	2005	EPA 508	mg/L	ND	0.00002	0.002	07/10/2014	SUB-5
† Glyphosate	2034	EPA 547	mg/L	ND	0.05	0.7	07/17/2014	SUB-5
† Heptachlor	2065	EPA 508	mg/L	ND	0.00002	0.0004	07/10/2014	SUB-5
† Heptachlor Epoxide	2067	EPA 508	mg/L	ND	0.00002	0.0002	07/10/2014	SUB-5
† Hexachlorobenzene	2274	EPA 525.2	mg/L	ND	0.0001	0.001	07/21/2014	SUB-5
† Hexachlorocyclopentadiene	2042	EPA 525.2	mg/L	ND	0.005	0.05	07/21/2014	SUB-5
† Lindane	2010	EPA 508	mg/L	ND	0.00002	0.0002	07/10/2014	SUB-5
† Methoxychlor	2015	EPA 508	mg/L	ND	0.0001	0.04	07/10/2014	SUB-5
† Oxamyl (Vydate)	2036	EPA 531.1	mg/L	ND	0.004	0.2	07/10/2014	SUB-5
† Pentachlorophenol	2326	EPA 515.3	mg/L	ND	0.0001	0.001	07/18/2014	SUB-5
† Picloram	2040	EPA 515.3	mg/L	ND	0.005	0.5	07/18/2014	SUB-5
† Polychlorinated biphenyls	2383	EPA 508	mg/L	ND	0.0001	0.0005	07/10/2014	SUB-5
† Simazine	2037	EPA 525.2	mg/L	ND	0.0004	0.004	07/21/2014	SUB-5
† Toxaphene	2020	EPA 508	mg/L	ND	0.0003	0.003	07/10/2014	SUB-5
Unregulated Analyte								
† 3-Hydroxycarbofuran	2066	EPA 531.1	mg/L	ND	0.004	-	07/10/2014	SUB-5



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

Reported: 07/24/2014
Received: 07/09/2014
Sampled By: LN/lab
Work Order: 4190032

C Parrett Mtn View Estates
L Attn: -
I 21881 River Rd. NE
E St Paul OR, 97137
N Phone: 503-633-2666
T


Project: -
Project # : N/A
PWSID # : 4101498

Sampling Location: LaBrousse Rd.
Sample Matrix: Drinking Water

Synthetic Organic Chemicals	Code	Method	Units	Result	MRL	EPA MCL	Analysis Date
† Aldicarb	2047	EPA 531.1	mg/L	ND	0.004	-	07/10/2014 SUB-5
† Aldicarb Sulfone	2044	EPA 531.1	mg/L	ND	0.004	-	07/10/2014 SUB-5
† Aldicarb sulfoxide	2043	EPA 531.1	mg/L	ND	0.004	-	07/10/2014 SUB-5
† Aldrin	2356	EPA 508	mg/L	ND	0.00002	-	07/10/2014 SUB-5
† Baygon		EPA 531.1	mg/L	ND	0.004	-	07/10/2014 SUB-5
† Butachlor	2076	EPA 525.2	mg/L	ND	0.0063	-	07/21/2014 SUB-5
† Carbaryl	2021	EPA 531.1	mg/L	ND	0.004	-	07/10/2014 SUB-5
† Dicamba	2440	EPA 515.3	mg/L	ND	0.005	-	07/18/2014 SUB-5
† Dieldrin	2070	EPA 508	mg/L	ND	0.00002	-	07/10/2014 SUB-5
† Methiocarb		EPA 531.1	mg/L	ND	0.004	-	07/10/2014 SUB-5
† Methomyl	2022	EPA 531.1	mg/L	ND	0.004	-	07/10/2014 SUB-5
† Metolachlor	2045	EPA 525.2	mg/L	ND	0.0004	-	07/21/2014 SUB-5
† Metribuzin	2595	EPA 525.2	mg/L	ND	0.0004	-	07/21/2014 SUB-5
† Propachlor	2077	EPA 525.2	mg/L	ND	0.0004	-	07/21/2014 SUB-5

ND = None detected **MRL** = Minimum Reporting Limit **MCL** = Maximum Contamination Limit
SUB-5 This analysis was subcontracted to Neilson Research Corporation ORELAP ID# OR100016

†All procedures for this analysis conform to NELAC standards.

Approved by: 
Scott Dickman
Lab Director

This report shall not be reproduced, except in full, without the written approval of the laboratory.