

**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT
ORELAP Accredited Lab#: OR-100013

Reported: 09/26/2016
Received: 09/08/2016
Sampled By: Home Owners
Work Order: 6252032

C Parrett Mtn View Estates
L Attn: Patrick Rosborough
I 18319 SW Salmonberry Dr.
E Sherwood OR, 97140
N Phone: (503) 625-1760
T


Project:
Project # : N/A
PWSID # : 4101498

Sampling Location: Owners Homes

Lab Number

Code	Method	Units	Result	MRL	EPA MCL	Analysis Date/ Time
6252032-01 Sample Name: 43 Mote Kitchen Matrix: Water Sampled: 9/5/16 7:32						
<i>Metals (Total)</i>						
+Copper	1055	SM3111B	mg/L	0.134	0.050 1.3	09/21/16 15:47
+Lead	1030	EPA 200.9	mg/L	0.0023	0.0020 0.015	09/19/16 16:54
6252032-02 Sample Name: 39 Harris Kitchen Matrix: Water Sampled: 9/5/16 8:55						
<i>Metals (Total)</i>						
+Copper	1055	SM3111B	mg/L	0.106	0.050 1.3	09/21/16 15:47
+Lead	1030	EPA 200.9	mg/L	0.0026	0.0020 0.015	09/19/16 16:54
6252032-03 Sample Name: 54 AlHoty Kitchen Matrix: Water Sampled: 9/5/16 15:30						
<i>Metals (Total)</i>						
+Copper	1055	SM3111B	mg/L	ND	0.050 1.3	09/21/16 15:47
+Lead	1030	EPA 200.9	mg/L	ND	0.0020 0.015	09/19/16 16:54
6252032-04 Sample Name: 20 Lobingier Kitchen Matrix: Water Sampled: 9/5/16 7:00						
<i>Metals (Total)</i>						
+Copper	1055	SM3111B	mg/L	0.107	0.050 1.3	09/21/16 15:47
+Lead	1030	EPA 200.9	mg/L	ND	0.0020 0.015	09/19/16 16:54
6252032-05 Sample Name: 8 Owen Kitchen Matrix: Water Sampled: 9/5/16 6:45						
<i>Metals (Total)</i>						
+Copper	1055	SM3111B	mg/L	0.149	0.050 1.3	09/21/16 15:47
+Lead	1030	EPA 200.9	mg/L	0.0028	0.0020 0.015	09/19/16 16:54

ND = None detected at the MRL MRL = Minimum Reporting Limit MCL = Maximum Contamination Limit
†All procedures for this analysis conform to NELAC standards.

Approved by: 
Adriana Gonzalez-Gray
Laboratory Director