

**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

Reported: 05/29/2012
Received: 05/14/2012
Sampled By: Homeowners
Work Order: 2135010

C Parrett Mtn View Estates
L Attn: Kriss Schneider c/o Management Trust NW
I 21881 River Rd NE
E St. Paul OR, 97137
N Phone: 503-633-2666
T

Project: Parrett Mountain View Estates
Project # : PMVE #1033
PWSID # : 4101498
PO # : -

Sampling Location: Houses
Sample Matrix: Drinking Water

Lab Number 2135010-01 **Sample Name** Migdol Lot 1 **Sampled:** 5/10/12 6:30 **Sample Composition:** Raw Distribution

Metals (Total)	Code	Method	Units	Result	MRL	EPA MCL	Secondary Standard*	Analysis Date/ Time
†Copper	1055	SM 3111B	mg/L	0.102	0.050	1.3	-	05/21/12 13:00
†Lead	1030	EPA 200.9	mg/L	ND	0.002	0.015	-	05/25/12 13:49

Lab Number 2135010-02 **Sample Name** Owen Lot 8 **Sampled:** 5/10/12 5:40 **Sample Composition:** Raw Distribution


Metals (Total)	Code	Method	Units	Result	MRL	EPA MCL	Secondary Standard*	Analysis Date/ Time
†Copper	1055	SM 3111B	mg/L	0.161	0.050	1.3	-	05/21/12 13:00
†Lead	1030	EPA 200.9	mg/L	ND	0.002	0.015	-	05/25/12 13:49

Lab Number 2135010-03 **Sample Name** Horton Lot 14 **Sampled:** 5/10/12 5:15 **Sample Composition:** Raw Distribution

Metals (Total)	Code	Method	Units	Result	MRL	EPA MCL	Secondary Standard*	Analysis Date/ Time
†Copper	1055	SM 3111B	mg/L	0.058	0.050	1.3	-	05/21/12 13:00
†Lead	1030	EPA 200.9	mg/L	ND	0.002	0.015	-	05/25/12 13:49

Lab Number 2135010-04 **Sample Name** Lobingier Lot 20 **Sampled:** 5/10/12 5:00 **Sample Composition:** Raw Distribution

Metals (Total)	Code	Method	Units	Result	MRL	EPA MCL	Secondary Standard*	Analysis Date/ Time
†Copper	1055	SM 3111B	mg/L	0.137	0.050	1.3	-	05/21/12 13:00
†Lead	1030	EPA 200.9	mg/L	ND	0.002	0.015	-	05/25/12 13:49



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

Reported: 05/29/2012
Received: 05/14/2012
Sampled By: Homeowners
Work Order: 2135010

C Parrett Mtn View Estates
L Attn: Kriss Schneider c/o Management Trust NW
I 21881 River Rd NE
E St. Paul OR, 97137
N Phone: 503-633-2666
T

Project: Parrett Mountain View Estates
Project # : PMVE #1033
PWSID # : 4101498
PO # : -

Sampling Location: Houses
Sample Matrix: Drinking Water

Lab Number 2135010-05 **Sample Name** Padden Lot 28 **Sampled:** 5/10/12 6:30 **Sample Composition:** Raw Distribution

Metals (Total)	Code	Method	Units	Result	MRL	EPA MCL	Secondary Standard*	Analysis Date/ Time
†Copper	1055	SM 3111B	mg/L	0.097	0.050	1.3	-	05/21/12 13:00
†Lead	1030	EPA 200.9	mg/L	ND	0.002	0.015	-	05/25/12 13:49

Lab Number 2135010-06 **Sample Name** Harris Lot 39 **Sampled:** 5/10/12 5:50 **Sample Composition:** Raw Distribution


Metals (Total)	Code	Method	Units	Result	MRL	EPA MCL	Secondary Standard*	Analysis Date/ Time
†Copper	1055	SM 3111B	mg/L	0.120	0.050	1.3	-	05/21/12 13:00
†Lead	1030	EPA 200.9	mg/L	ND	0.002	0.015	-	05/25/12 13:49

Lab Number 2135010-07 **Sample Name** Mote Lot 43 **Sampled:** 5/10/12 6:00 **Sample Composition:** Raw Distribution

Metals (Total)	Code	Method	Units	Result	MRL	EPA MCL	Secondary Standard*	Analysis Date/ Time
†Copper	1055	SM 3111B	mg/L	0.051	0.050	1.3	-	05/21/12 13:00
†Lead	1030	EPA 200.9	mg/L	ND	0.002	0.015	-	05/25/12 13:49

Lab Number 2135010-08 **Sample Name** Marks Lot 48 **Sampled:** 5/10/12 8:00 **Sample Composition:** Raw Distribution

Metals (Total)	Code	Method	Units	Result	MRL	EPA MCL	Secondary Standard*	Analysis Date/ Time
†Copper	1055	SM 3111B	mg/L	0.090	0.050	1.3	-	05/21/12 13:00
†Lead	1030	EPA 200.9	mg/L	0.002	0.002	0.015	-	05/25/12 13:49



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

Reported: 05/29/2012
Received: 05/14/2012
Sampled By: Homeowners
Work Order: 2135010

C **Parrett Mtn View Estates**
L Attn: Kriss Schneider c/o Management Trust NW
I 21881 River Rd NE
E St. Paul OR, 97137
N Phone: 503-633-2666
T

Project: Parrett Mountain View Estates
Project # : PMVE #1033
PWSID # : 4101498
PO # : -

Sampling Location: Houses
Sample Matrix: Drinking Water

Lab Number	Sample Name	Sampled: 5/10/12 9:30		Sample Composition: Raw Distribution				
2135010-09	Benner Lot 56							
Metals (Total)	Code	Method	Units	Result	MRL	EPA MCL	Secondary Standard*	Analysis Date/ Time
†Copper	1055	SM 3111B	mg/L	0.130	0.050	1.3	-	05/21/12 13:00
†Lead	1030	EPA 200.9	mg/L	ND	0.002	0.015	-	05/25/12 13:49

Lab Number	Sample Name	Sampled: 5/10/12 5:30		Sample Composition: Raw Distribution				
2135010-10	Geer Lot 66							
Metals (Total)	Code	Method	Units	Result	MRL	EPA MCL	Secondary Standard*	Analysis Date/ Time
†Copper	1055	SM 3111B	mg/L	0.646	0.050	1.3	-	05/21/12 13:00
†Lead	1030	EPA 200.9	mg/L	ND	0.002	0.015	-	05/25/12 13:49

† All procedures for this analysis conform to NELAC standards.

ND = None detected **MRL** = Minimum Reporting Limit **MCL** = Maximum Contaminant Limit

Approved by: _____

Scott Dickman
Lab Director

This report shall not be reproduced, except in full, without the written approval of the laboratory.