

**Professional  
Laboratory  
Services**

**ANALYSIS REPORT**  
ORELAP Accredited Lab#: OR-100013

13035 SW Pacific Hwy.  
Tigard, OR 97223  
Tel.: (503) 639-9311 Fax: (503) 684-1588

Reported: 05/02/2012  
Sampled: 04/18/12  
Received: 04/18/12  
Sampled By: LN/Lab  
Work Order: 2109019

**C  
L  
I  
E  
N  
T**

**Parrett Mtn View Estates**  
Attn: Kriss Schneider c/o Management Trust NW  
21881 River Rd NE  
St. Paul OR, 97137  
Phone: 503-633-2666

Project # : N/A  
PWSID # : 4101498

**Project:** -  
Sample Name: Well house inside HB  
Source ID: Parrett Mtn. View Estates  
Method: EPA 524.2  
Analyst: AGG

Sample Composition:

**Volatile Organic Compounds**

**Regulated VOC's**

Laboratory Sample ID :2109019-01

Sample Analyzed: 05/01/2012

<u>Contaminant</u>	<u>Code</u>	<u>MRL (mg/L)</u>	<u>Sample Results (mg/L)</u>	<u>MCL (mg/L)</u>
1,1,1-Trichloroethane	2981	0.0005	ND	0.2000
1,1,2-Trichloroethane	2985	0.0005	ND	0.0050
1,1-Dichloroethylene	2977	0.0005	ND	0.0070
1,2,4-Trichlorobenzene	2378	0.0005	ND	0.0700
1,2-Dichlorobenzene	2968	0.0005	ND	0.6000
1,2-Dichloroethane	2980	0.0005	ND	0.0050
1,2-Dichloropropane	2983	0.0005	ND	0.0050
1,4-Dichlorobenzene	2969	0.0005	ND	0.0750
Benzene	2990	0.0005	ND	0.0050
Carbon tetrachloride	2982	0.0005	ND	0.0050
Chlorobenzene	2989	0.0005	ND	0.1000
cis-1,2-Dichloroethylene	2380	0.0005	ND	0.0700
Ethyl Benzene	2992	0.0005	ND	0.0700
Methylene chloride	2964	0.0005	ND	0.0050
Styrene	2996	0.0005	ND	0.1000
Tetrachloroethylene	2987	0.0005	ND	0.0050
Toluene	2991	0.0005	ND	1.0000
trans-1,2-Dichloroethylene	2979	0.0005	ND	0.1000
Trichloroethylene	2984	0.0005	ND	0.0050
Vinyl chloride	2976	0.0005	ND	0.0050
Xylenes, total	2955	0.0015	ND	10.000

ND = None detected

MRL = Minimum Reporting Limit

MCL = Maximum Contamination Limit


Approved by:

Adriana Gonzalez-Gray  
Organic Technical Director

Reviewed by:

Scott Dickman  
Lab Director

*This report reflects the results of these samples only. This report shall not be reproduced, except in full, without the written approval of the laboratory. All procedures for this report conform to NELAC standards*



Professional Laboratory Services

13035 SW Pacific Hwy.
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

Reported: 05/02/2012
Sampled: 04/18/12
Received: 04/18/12
Sampled By: LN/Lab
Work Order: 2109019

C
L
I
E
N
T

Parrett Mtn View Estates

Attn: Kriss Schneider c/o Management Trust NW
21881 River Rd NE
St. Paul OR, 97137
Phone: 503-633-2666

Project #: N/A
PWSID #: 4101498

Project: -
Sample Name: Well house inside HB
Source ID: Parrett Mtn. View Estates
Method: EPA 524.2
Analyst: AGG

Sample Composition:

Volatile Organic Compounds

Unregulated VOC's

Laboratory Sample ID : 2109019-01

Table with 6 columns: Contaminant, MRL (mg/L), Sample Results (mg/L), Contaminant, MRL (mg/L), Sample Results (mg/L). Lists various VOCs and their detection status.

ND = None detected MRL = Minimum Reporting Limit

Special Notes

Approved by: [Signature]
Adriana Gonzalez-Gray
Organic Technical Director

Reviewed by: [Signature]
Scott Dickman
Lab Director

This report reflects the results of these samples only. This report shall not be reproduced, except in full, without the written approval of the laboratory.
All procedures for this report conform to NELAC standards