

**Professional  
Laboratory  
Services**

13035 SW Pacific Hwy  
Tigard, OR 97223  
Tel.: (503) 639-9311 Fax: (503) 684-1588

**ANALYSIS REPORT**

ORELAP Accredited Lab#: OR-100013

Reported: 07/31/2013  
Received: 07/23/2013  
Sampled By:  
Work Order: 3204027

**Project:** -  
Project #: N/A  
PWSID #: 4101498  
PO #: -

Sampling Location: -  
Sample Matrix: Water

**C** Parrett Mtn View Estates  
**L** Attn: -  
**I** 21881 River Rd. NE  
**E** St Paul OR, 97137  
**N** Phone: 503-633-2666  
**T**

**Lab Number** 3204027-01 **Sample Name** Owen Lot 8 **Sampled:** 7/21/13 6:58 **Sample Composition:**

Metals (Total)	Code	Method	Units	Result	MRL	EPA MCL	Secondary Standard*	Analysis Date/ Time
†Copper	1055	SM 3111B	mg/L	0.079	0.050	1.3	-	07/30/13 12:50
†Lead	1030	EPA 200.9	mg/L	0.003	0.002	0.015	-	07/24/13 13:06

**Lab Number** 3204027-02 **Sample Name** Lobingier Lot 20 **Sampled:** 7/21/13 15:15 **Sample Composition:**


Metals (Total)	Code	Method	Units	Result	MRL	EPA MCL	Secondary Standard*	Analysis Date/ Time
†Copper	1055	SM 3111B	mg/L	ND	0.050	1.3	-	07/30/13 12:50
†Lead	1030	EPA 200.9	mg/L	ND	0.002	0.015	-	07/24/13 13:06

**Lab Number** 3204027-03 **Sample Name** Harris Lot 39 **Sampled:** 7/21/13 8:00 **Sample Composition:**

Metals (Total)	Code	Method	Units	Result	MRL	EPA MCL	Secondary Standard*	Analysis Date/ Time
†Copper	1055	SM 3111B	mg/L	0.153	0.050	1.3	-	07/30/13 12:50
†Lead	1030	EPA 200.9	mg/L	0.004	0.002	0.015	-	07/24/13 13:06

**Lab Number** 3204027-04 **Sample Name** Marks Lot 48 **Sampled:** 7/21/13 6:00 **Sample Composition:**

Metals (Total)	Code	Method	Units	Result	MRL	EPA MCL	Secondary Standard*	Analysis Date/ Time
†Copper	1055	SM 3111B	mg/L	0.088	0.050	1.3	-	07/30/13 12:50
†Lead	1030	EPA 200.9	mg/L	0.004	0.002	0.015	-	07/24/13 13:06



**Professional  
Laboratory  
Services**

13035 SW Pacific Hwy  
Tigard, OR 97223  
Tel.: (503) 639-9311 Fax: (503) 684-1588

**ANALYSIS REPORT**

ORELAP Accredited Lab#: OR-100013

Reported: 07/31/2013  
Received: 07/23/2013  
Sampled By:  
Work Order: 3204027

**Project:** -  
Project #: N/A  
PWSID #: 4101498  
PO #: -

Sampling Location: -  
Sample Matrix: Water

**C** Parrett Mtn View Estates  
**L** Attn: -  
**I** 21881 River Rd. NE  
**E** St Paul OR, 97137  
**N** Phone: 503-633-2666  
**T**

**Lab Number** 3204027-05 **Sample Name** Geer Lot 66 **Sampled:** 7/21/13 8:05 **Sample Composition:**

Metals (Total)	Code	Method	Units	Result	MRL	EPA MCL	Secondary Standard*	Analysis Date/ Time
†Copper	1055	SM 3111B	mg/L	0.512	0.050	1.3	-	07/30/13 12:50
†Lead	1030	EPA 200.9	mg/L	ND	0.002	0.015	-	07/24/13 13:06

† All procedures for this analysis conform to NELAC standards.

**ND** = None detected

**MRL** = Minimum Reporting Limit

**MCL** = Maximum Contaminant Limit

Approved by:

Scott Dickman  
Lab Director

This report shall not be reproduced, except in full, without the written approval of the laboratory.